



ADDENDUM NO.2

Date: 2-12-2012

Owner: City of Bellmead

Project Name: TX Cap Fund Downtown Revitalization Project 710142
Downtown Sidewalk and ADA Improvements

This Addendum forms part of the Contract and clarifies, corrects or modifies the original Construction Documents, dated January 19, 2012. Acknowledge receipt of this addendum in space provided below by affixing your "Signature and Date" below and submit with your bid. Failure to do so may subject bidder to disqualification.

1. Revised Bid Form:

This Addenda provides a revised Bid Form to include the following bid items:

- a. Mobilization
- b. Barricades, Signs and Traffic Handling

2. Temporary Sediment Control Fence:

No formal erosion control plan was required. There are no inlets requiring protection and contractors will need to coordinate with City (i.e. utilize their facilities) for staging, construction entrances, and washout. Token amount (per TxDOT) of silt fence was added for instances where possible subsidiary protection might appear during the course of construction.

3. Traffic Control:

Majority of construction occurs within right-of-way and should not affect major traffic flow. Traffic Control considerations should be taken only at intersection corners and side streets for striping and ramp installation. No specific traffic control items were designated. Coordination with City and TxDOT shall be made by contractors as needed.

4. Block Sodding:

Sodded areas were introduced per TxDOT suggestions and will be maintained and watered by City per maintenance agreement.


5. Street Lamps:

Posts will be anchored by 24" bolts provided by post manufacturers that will be directly embedded into existing concrete areas shown on the plans. No new bases will be formed. Street lamp locations were designated at only available existing power source options along route. Contractors will coordinate with Oncor Electric and City to establish drops from the nearby power poles to service the proposed street lamps. All connections will follow NEC specifications and comply with TxDOT and City regulations for illumination limits.

6. Traffic Signals:

For Alternate Bid, the bid request is for ped head and push button installation on existing traffic signal poles that have an existing power source and box.

This addendum consists of 4 pages (including Bid Form).


Signature of Engineer

Fax this page to (512) 244-9623

Received

Date

Company Name